

**BEFORE THE NATIONAL GREEN TRIBUNAL,  
PRINCIPAL BENCH, NEW DELHI**

**Original Application No. 94 of 2013  
(Noticee No. 7, 8, 9, 10 & 18)  
M.A. Nos. 904/2014, 592/2015 & 806/2015**

**Vikrant Kumar Tongad Vs. Union of India & Ors.**

**CORAM: HON'BLE MR. JUSTICE U.D. SALVI, JUDICIAL MEMBER  
HON'BLE MR. RANJAN CHATTERJEE, EXPERT MEMBER**

**Present:**

<b>Applicant / Appellant</b>	<b>:Mr. Rahul Choudhary, Adv.</b>
<b>Sanjay Gandhi Memorial Hospital</b>	<b>:Dr. Avneendra Prasad</b>
<b>Saket City Hospital</b>	<b>:Mr. Ravikesh K. Sinha, Adv.</b>
<b>SDMC</b>	<b>:Ms. Puja Kalra, Adv.</b>
<b>CPWD</b>	<b>:Mr. A. Kumar Prasad, Jigdaj Chankapa, Priyanka Swami, Adv.</b>
<b>CGWA</b>	<b>:Mr. B.V. Niren, CGSC</b>
<b>Respondent No. 6</b>	<b>:Ms. Reena Singh, AAG of UP and Ms. Bhakti Pasrija Sethi, Adv.</b>
<b>Jai Prakash Narayan Apex Toarma Centre, AIIMS</b>	<b>: Mr. R.K.Gupta, Adv.</b>

<b>Date and Remarks</b>	<b>Orders of the Tribunal</b>
<b>Item No. 10 September 15, 2015</b>	<p>Notice was issued to the Institute of Liver &amp; Biliary Sciences, upon noticing that there were two rain water harvesting systems out of which one was abandoned and STP water was allowed to be stagnated in the rain water harvesting system. It was further noticed that one structure that was available for rain water harvesting system was insufficient. This fact was noticed on 4.2.2015. On 8.6.2015, four months later, it was observed that rain water harvesting system was in place and it gave satisfactory results. Nothing is before us to point out that whether untreated water from the STP was coming into rain water harvesting system. We, therefore, assume otherwise in favour of the hospital. Considering these facts and circumstances, we do not see any reason to pass any direction for payment of compensation. Noticee is discharged.</p>

List this matter on 24<sup>th</sup> September, 2015.

.....,JM  
(U.D. Salvi)

.....,EM  
(Ranjan Chatterjee)

